



B-PRO 4000 Multi-Busbar Firmware

v1.2

Release Description

DATE: 2022-06-10

FEATURE ENHANCEMENTS

- Cyber Security
 - Added a message to the event log for user login attempts.
- General
 - Added the ability to receive MMS Single Point Control (SPC) latched commands from IEC 61850 clients.
 - Added support for C37.118-2011 compliant IRIG clock sources.
 - Updated the default setting file to disable all Target LED assignments in the Output Matrix.
 - Optimized event handling on the display to improve performance when the IED is heavily loaded.
 - Improved ability to recover from cases where the front screen goes blank or is disturbed after extreme transient conditions.
 - Enhanced IED health monitoring capabilities to detect and automatically recover when the IED isn't behaving as expected.
 - Added error checking to detect and decline invalid calibration values during analog inputs calibration process.

CORRECTIONS TO ISSUES

- Cyber Security
 - None.
- General
 - Major: Added a mechanism to prevent the unit from continuously restarting when no valid setting file is found. The unit enters a "survival" mode that allows the user to login and reset to factory default.
 - Minor: 59 function trip status mapping corrected by moving the assignment from the Str to the Op Data Attribute for the IEC 61850 D59TOV1 and D059TOV2 Logical Nodes.

ERLPhase Power Technologies Customer Support Contact Information

support@erlphase.com

+1 (204) 477-0591 Option 1

www.erlphase.com



COMPATIBILITY

B-PRO 4000 Multi Busbar Offliner Software:	v1.1 and above
Relay Control Panel Software:	v3.4 and above
RecordGraph Software:	v5.1 and above
RecordBase Central Station Software:	v4.1 and above
RecordBase View Software:	v4.2 and above
61850 IED Configurator Software:	v3.5 Rev 1 and above
ICD File Version	v3.1 Rev 02
B-PRO 4000 Multi Busbar Setting Version	402
B-PRO 4000 Multi Busbar User Manual	v1.2 Rev 0

Minor releases, designated with a revision or letter (e.g. v3.4 Rev 1 or v3.4a), maintain the same compatibility as their base version (e.g. v3.4 Rev 0 or v3.4).

REVISION HISTORY

v1.1 – 2017-11-06

- Initial release for general availability.

v1.0 – 2014-08-28

- Beta release. Not for general availability.

CLASSIFICATION OF CHANGES MADE

The issues fixed in software / firmware upgrades are classified as defined below. While it is always the user's decision to upgrade installed products, these classifications provide a guideline for the need and priority of the upgrade.

Critical: Critical changes fix issues/problems that prevent the basic operation of the device and have no workaround. Critical changes merit a product upgrade as soon as possible, if that function is being used under the conditions causing the issue

Major: Major changes fix problems that prevent the basic operation of the device but do have a workaround. Any major changes merit a product upgrade as soon as possible if the function is being used under the conditions causing the issue and a workaround is not acceptable.

Minor: Minor changes fix non vital issues that do not prevent the basic operation of the device and may or may not have a workaround. Product upgrades for such changes are not necessary unless they apply to and are needed by the user.

Enhancement: Feature enhancements add a capability or extend existing capabilities of the product. Upgrades for such changes need be made only if and when that feature enhancement is desired.

ERLPhase Power Technologies Customer Support Contact Information

support@erlphase.com

+1 (204) 477-0591 Option 1

www.erlphase.com