



F-PRO 116 Firmware

v1.2

Release Description

DATE: 2022-01-12

FEATURE ENHANCEMENTS

- Cyber Security:
 - Added password protection for setting file upload.
- General:
 - Added 50N1, 50N2, 51N Protection Functions.
 - Added DNP 3.0 serial communication protocol for SCADA communication.
 - Added event pop-up messages on the front panel display.
 - Added the ability to update the firmware via the front USB port.

CORRECTIONS TO ISSUES

- Cyber Security:
 - None.
- General:
 - Minor: Fixed issue where loading the Setting File to the unit without selecting the Setting Group in the terminal user interface would result in an unexpected unit restart.

COMPATIBILITY

F-PRO 2000 Offliner Settings Software	v3.1and above
Setting Version	2
F-PRO 116 User Manual	v1.2 Rev 0

Minor releases, designated with a revision or letter (e.g. v3.4 Rev 1 or v3.4a), maintain the same compatibility as their base version (e.g. v3.4 Rev 0 or v3.4).

ERLPhase Power Technologies Customer Support Contact Information

support@erlphase.com

+1 (204) 477-0591 Option 1

www.erlphase.com



REVISION HISTORY

v1.1 – 2021-02-11

- Enhancement: Added the ability to set the Real Time Clock (RTC) via the front panel USB-serial interface.
- Enhancement: Added support for Tera Term terminal emulator software from front panel USB-serial interface.

v1.0 – 2020-08-01

- Enhancement: Initial release for general availability.

CLASSIFICATION OF CHANGES MADE

The issues fixed in software / firmware upgrades are classified as defined below. While the decision to upgrade installed products is the user's, these classifications provide a guideline for the need and priority of the upgrade.

Critical: Critical changes fix issues/problems that prevent the basic operation of the device and have no workaround. Critical changes merit a product upgrade as soon as possible, if that function is being used under the conditions causing the issue

Major: Major changes fix problems that prevent the basic operation of the device but do have a workaround. Any major changes merit a product upgrade as soon as possible if the function is being used under the conditions causing the issue and a workaround is not acceptable.

Minor: Minor changes fix non vital issues that do not prevent the basic operation of the device and may or may not have a workaround. Product upgrades for such changes are not necessary unless they apply to and are needed by the user.

Feature Enhancement: Feature enhancements add a capability or extend existing capabilities of the product. Upgrades for such changes need be made only if and when that feature enhancement is desired.

ERLPhase Power Technologies Customer Support Contact Information

support@erlphase.com

+1 (204) 477-0591 Option 1

www.erlphase.com