



# F-PRO 5100 Feeder Protection Relay

## Firmware v4.0

### Release Description

#### DESCRIPTION

F-PRO 5100 firmware release to enhance cyber security capabilities.

#### FEATURE ENHANCEMENTS

- Added a security administrator user with local and remote access, having sole control of mandatory passwords for all users. Removed password change rights for all other users.
- Added requirement that all users must have a password. A zero length password is no longer accepted.
- Added cyber security event logging to an external syslog server. Syslog server message protocol is compliant with RFC 5424 and RFC 5426.
- Disabled all unused TCP ports. Only telnet port (port 23) remains enabled.
- Maximum password length increased to 22 characters.
- Added 5 minute login lockout after 7 consecutive failed login attempts.
- Added subnet mask and default gateway IP address preservation during firmware update.
- Added capability to preserve all relay setup parameters during Firmware update.

#### CORRECTIONS TO ISSUES

- **Minor:** Made some text corrections on the maintenance menu screen: item 5 text was too long and being truncated; missing '\*' indicator for items that are only accessible on port 1.
- **Minor:** Corrected issue where maintenance System Utility screen referred to incorrect support email address.

#### COMPATIBILITY:

Compatible F-PRO 4000 Offliner Settings Software	v1.0 or above
Compatible RecordBase View Software	v1.4 or above

Minor releases, designated with a revision (e.g. v3.4 Rev 1), maintain the same compatibility as their base version (e.g. v3.4 Rev 0).

ERLPhase Power Technologies Customer Support Contact Information

[support@erlphase.com](mailto:support@erlphase.com)

204-477-0591 x1

[www.erlphase.com](http://www.erlphase.com)



## CLASSIFICATION OF CHANGES MADE

The issues fixed in software / firmware upgrades are classified as defined below. While the decision to upgrade installed products is the user's, these classifications provide a guideline for the need and priority of the upgrade.

**Critical:** Critical changes fix issues/problems that prevent the basic operation of the device and have no workaround. Critical changes merit a product upgrade as soon as possible, if that function is being used under the conditions causing the issue

**Major:** Major changes fix problems that prevent the basic operation of the device but do have a workaround. Any major changes merit a product upgrade as soon as possible if the function is being used under the conditions causing the issue and a workaround is not acceptable.

**Minor:** Minor changes fix non vital issues that do not prevent the basic operation of the device and may or may not have a workaround. Product upgrades for such changes are not necessary unless they apply to and are needed by the user.

**Feature Enhancement:** Feature enhancements add a capability or extend existing capabilities of the product. Upgrades for such changes need be made only if and when that feature enhancement is desired.

ERLPhase Power Technologies Customer Support Contact Information

[support@erlphase.com](mailto:support@erlphase.com)

204-477-0591 x1

[www.erlphase.com](http://www.erlphase.com)