



## T-PRO 4000 Firmware

v1.3

### Release Description

**DATE: 2019-11-29**

#### FEATURE ENHANCEMENTS

- Cyber Security:
  - Added a message to the event log for user login attempts.
  - Removed “View” user password requirement on the front panel so that users may access read-only parameters without needing to login using a password.
- General:
  - Added support for C37.118-2011 compliant IRIG clock sources.
  - Added the ability to switch between the target event screen and the menu screens on the front panel display to prevent target events from locking the screen.
  - Updated the default setting file to disable all Target LED assignments in the Output Matrix.
  - Optimized event handling on the display to improve performance when the IED is heavily loaded.
  - Improved ability to recover from cases where the front screen goes blank or is disturbed after extreme transient conditions.

#### CORRECTIONS TO ISSUES

- Cyber Security:
  - None.
- General:
  - **Major:** Fixed issue where External Inputs failed to turn on their assigned Target LEDs.



## COMPATIBILITY:

T-PRO Offliner	v1.5 or above
Relay Control Panel	v2.5 or above
RecordBase View	v3.2 or above
RecordBase Central Station:	v4.1 or above
Product Manual:	v1.3 or above
ERL 61850 IED Configurator	v2.0 Rev 1 or above

Minor releases, designated with a letter suffix (e.g. v3.1a), maintain the same compatibility as the base version (e.g. v3.1=v3.1a).

## REVISION HISTORY

### v1.2b - 2017-06-09

- **Enhancement:** Add support for enhanced hardware for production use.

### v1.2a - 2015-02-14

- **Enhancement:** Supports IRIG external clock sources compliant with C37.118-2005.
- **Enhancement:** Directional earth fault 67N protection feature addition.
- **Enhancement:** Phase segregated trip information in data recording, accessible through Prologic and Output Matrix.
- **Enhancement:** User interface enhancements for new feature support and general functional improvement.
- **Enhancement:** LED and metering enhancements.
- **Enhancement:** DC removal filter for overcurrent elements.
- **Enhancement:** Dual SNTP time server support.
- **Major:** Corrected date processing when time source is internal clock.
- **Major:** IEC 61850 and DNP communications enhancements and corrections.

### v1.2 - Not Released

### v1.1 - 2014-05-05

- **Enhancement:** Zig Zag transformer configuration support.
- **Enhancement:** Device GUI enhancements for new feature support and general functional improvement.
- **Major:** Modification to trend metering channel definition structure eliminating potential for unit soft restart under successive setting file loads. Firmware update is recommended.
- **Major:** Adjusted Modbus RTU Communication Protocol scaling factor for Read Holding Registers to compensate for higher turns ratio.

ERLPhase Power Technologies Customer Support Contact Information

[support@erlphase.com](mailto:support@erlphase.com)

204-477-0591 x1

[www.erlphase.com](http://www.erlphase.com)



## CLASSIFICATION OF CHANGES MADE

The issues fixed in software / firmware upgrades are classified as defined below. While the decision to upgrade installed products is the user's, these classifications provide a guideline for the need and priority of the upgrade.

**Critical:** Critical changes fix issues/problems that prevent the basic operation of the device and have no workaround. Critical changes merit a product upgrade as soon as possible, if that function is being used under the conditions causing the issue

**Major:** Major changes fix problems that prevent the basic operation of the device but do have a workaround. Any major changes merit a product upgrade as soon as possible if the function is being used under the conditions causing the issue and a workaround is not acceptable.

**Minor:** Minor changes fix non vital issues that do not prevent the basic operation of the device and may or may not have a workaround. Product upgrades for such changes are not necessary unless they apply to and are needed by the user.

**Feature Enhancement:** Feature enhancements add a capability or extend existing capabilities of the product. Upgrades for such changes need be made only if and when that feature enhancement is desired.

ERLPhase Power Technologies Customer Support Contact Information

[support@erlphase.com](mailto:support@erlphase.com)

204-477-0591 x1

[www.erlphase.com](http://www.erlphase.com)